



SECTION - 'A-A'

3/3.5/4 X 300 - 400	100	10	5	850
3/3.5/4 X 150 - 240	90	10	5	750
3/3.5/4 X 70 - 120	90	10	5	600
3/3.5/4 X 25 - 50	60	10	5	450
3/3.5/4 X 6 - 16	50	10	5	400
CABLE SIZE SQ. mm	L1	L2	L3	L

CABLE CUTTING DIMENSIONS

L3	LENGTH OF BARE CONDUCTOR
L2	LENGTH OF INNER SHEATH
L1	LENGTH OF ARMOUR

LEGEND

8	DETAIL INSTRUCTION MANUAL
7	PVC - NA - TAPE
6	EARTHING ARRANGEMENT :- 'A' TINNED COPPER BRAIDED 'B' JUBILEE CLAMPS FOR CLAMPING COPPER BRAID OVER ARMOUR 'C' MASTIC SEALING TAPE (TO BE APPLIED OVER THE CLAMPING AREA 'D' COPPER BINDING WIRE.
5	INLINE CONNECTOR CRIMPING TAPE COPPER IN CASE OF COPPER CABLES A1. IN CASE OF A1 CABLES
4	MASTIC SEALING STRIP
3	H.S. INSULATING TUBING FOR FERRULE PEGIDI
2	G. I. WIRE MESH TAPE
1	HEAT SHRINKABLE OUTER JACKETING SLEEVE
S.No.	DESCRIPTION OF KIT CONTENTS

A-1 ELECTRICALS

RAJKOT - 360001, Gujarat (India)

HEAT SHRINKABLE STRAIGHT THROUGH JOINT SUITABLE FOR LOW VOLTAGE PVC/XLPE CABLES (1100 V)



SCALE : NTS

ESTION No. : 00

DRG. No. A-1/01/A/09

LINE No. - 0001 UPTO 0016 / 0022 UPTO 0035

Drawn By: *Pr. Singh* CKD. BY: APPD. BY: DATE: 08/01/09